



VERTICAL SIDING AS PER OWNER'S SELECTION,
 2"x4" STRAPPING @ 24" O/C
 AIR BARRIER: TYVEK OR EQUAL
 1/16" OSB WALL SHEATHING
 2x6 WOOD STUDS @ 16" O/C
 R-22 INSULATION
 6 ML POLY VAPOUR BARRIER
 1/2" GYPSUM BOARD

WOOD STEPS AS
 REQUIRED BY
 GRADE

PRE-FINISHED FIBERGLASS POST
 AS PER OWNER'S SELECTION, (TYP)
 6"x6" PRESSURE TREATED POST
 SITTING IN 'SIMPSON STRONG TIE'
 GARPORT SADDLE GROUT INTO
 CONG SLAB (TYP)

2
 A2.2

- GENERAL NOTES:**
- SEE SUPPLIER ENGINEERING DATA FOR ENGINEERED WOOD, HEADERS, BEAMS AND WOOD IS.
 - ALL WINDOW AND DOOR LINTELS SHALL GRADE 2-2'x10" UNLESS NOTED OTHERWISE THESE PLANS.
 - ROOF SUPPLIER TO PROVIDE LINTEL SLOPE OVEROPENINGS WHERE ROOF TRUSS SPACING IS 19.8M IN ACCORDANCE WITH CBC 9.23.12.3.
 - ALL EXTERIOR CONCRETE TO BE MINIMUM 3000 PSI WITH 5% AIR ENTRAINMENT.
 - ALL INTERIOR & EXTERIOR STAIRS TO COMPLY WITH O.B.C. 9.0.2 AND HAVE A MINIMUM HEAD CLEARANCE OF 6'-5" WITHIN DWELLING UNITS.